

Notched flashing fixed with 12g x 25mm type 17 or 4.8mmØ aluminium rivets every rib

Climaseal coated self drilling 12g x 65mm tek screw

Dimond Brownbuilt 900 roof cladding (specify thickness and coating)

Roofing underlay and netting shown dashed

DHS girt

Line of structure

Notes:

- Foam closure strip only required if bird or vermin proofing is required, or if in a high wind area, there is a risk of windblown moisture entering the building.
- Leave foam out if ventilation is required.
- These details are suitably fixed to allow for a theoretical thermal movement of up to 10mm. For thermal movement greater than this a clipping system should be considered.

130 mm min. medium wind speed areas or pitches greater than 10°.
200 mm min. high wind speed areas and higher or pitches less than 10°.

Sheet lipped

Sheet lipped

100 mm min. lap

Climaseal coated self drilling 12g x 25mm T17 screw pan fixed

Foam closure strip on top of roofing (see note below)

Framing shown dashed for clarity

Dimond hi-span steel wall girt

Climaseal coated self drilling 12g x 20mm tek screw pan fixed

Dimond Brownbuilt 900 roof cladding (specify thickness and coating)

Building wrap shown dashed

Original Size A4



Brownbuilt 900

Roof

Roof - Wall Apex

File:	
Issue:	04
Scale:	1 : 5
Date:	05 October 2018
Reference	
dim_bb9_1060	