



Notes:

- Foam closure strip only required if bird or vermin proofing is required, or if in a high wind area, there is a risk of windblown moisture entering the building.
- Leave foam out if ventilation is required.
- These details are suitably fixed to allow for a theoretical thermal movement of up to 10mm. For thermal movement greater than this a clipping system should be considered.

Original Size A4



Brownbuilt 900 Wall

Horizontal Cavity Cladding - Wall/Roof Junction

File:	
Issue: 04	
Scale: 1 : 5	Reference
Date: 05 October 2018	dim_bb9_2180