

Notched flashing fixed with
4.8mmØ aluminium rivets at
1000mm centers max

Dimondek 300 clip fixed with 10g x
16mm wafer head tek screw

Dimondek® 300 roof (specify
thickness and coating)

Roofing underlay and netting
shown dashed

130 mm min. medium wind speed areas or pitches greater than 10°.
200 mm min. high wind speed areas and higher or pitches less than 10°.

Dimondek 300 stop ended

Dimondek 300 stop ended

100 mm min. lap

Dimondek 300 clip fixed with 10g x
16mm wafer head tek screw

Framing shown dashed for clarity

Dimond hi-span steel wall girt

Dimondek 300 clip fixed with 10g x
16mm wafer head tek screw

Dimondek® 300 wall cladding
(specify thickness and coating)

Building wrap shown dashed

DHS girt

Line of structure

Notes:

- Foam closure strip only required if bird or vermin proofing is required, or if in a high wind area, there is a risk of windblown moisture entering the building.
- Leave foam out if ventilation is required.
- These details are suitably fixed to allow for a theoretical thermal movement of up to 10mm. For thermal movement greater than this a clipping system should be considered.

Original Size A4



Dimondek 300

Roof

Roof - Wall Apex

File:	
Issue:	01
Scale:	1 : 5
Date:	28 November 2018
Reference	dim_dd3_1060