



- Notes:
- Foam closure strip only required if bird or vermin proofing is required, or if in a high wind area, there is a risk of windblown moisture entering the building.
  - Leave foam out if ventilation is required.
  - These details are suitably fixed to allow for a theoretical thermal movement of up to 10mm. For thermal movement greater than this a clipping system should be considered.

Original Size A4



# DP955 Wall

Horizontal Cavity Cladding - Wall/Roof Junction

|        |                  |                                      |
|--------|------------------|--------------------------------------|
| File:  |                  | Reference<br><br><b>dim_dp9_2180</b> |
| Issue: | 01               |                                      |
| Scale: | 1 : 5            |                                      |
| Date:  | 28 November 2018 |                                      |