



Notes:

- Foam closure strip only required if bird or vermin proofing is required, or if in a high wind area, there is a risk of windblown moisture entering the building.
- These details are suitably fixed to allow for a theoretical thermal movement of up to 10mm. For thermal movement greater than this a clipping system should be considered.
- Where CCA or ACQ treated cavity battens are installed a barrier between the batten and the cladding is required.

Plot Date: 22 Nov 2018

Original Size A4



Styleline Roof

Wall - Roof Junction (90 deg) on Cavity

File:	
Issue:	draft
Scale:	1 : 5
Date:	14 November 2018
Reference dim_snv_1051	