

Notched flashing fixed with  
4.8mmø aluminium rivets or M6 x  
25 Roofzip every rib

Climaseal coated self drilling M6 x  
65 Roofzip

Dimond LT5 Roofing (specify  
thickness and coating)

Roofing underlay and netting  
shown dashed

130 mm min. medium wind speed areas or pitches greater than 10°.  
200 mm min. high wind speed areas and higher or pitches less than 10°.

DHS girt

Line of structure

Notes:

- Foam closure strip only required if bird or vermin proofing is required, or if in a high wind area, there is a risk of windblown moisture entering the building.
- Leave foam out if ventilation is required.
- These details are suitably fixed to allow for a theoretical thermal movement of up to 10mm. For thermal movement greater than this a clipping system should be considered.

Dimond LT5 roofing stop ended

Dimond LT5 wall cladding stop ended

Climaseal coated self drilling M6 x  
50 Roofzip pan fixed

Foam closure strip on top of  
roofing (see note below)

Framing shown dashed for clarity

Dimond hi-span steel wall girt

Climaseal coated self drilling 12g x  
35mm tek screw pan fixed

Dimond LT5 wall cladding (specify  
thickness and coating)

Building wrap shown dashed

100 mm min. lap

Original Size A4



LT5  
Roof

Roof - Wall Apex

dim_lt5_1060 Roof - Wall Apex	
Issue: 01	Reference  <b>dim_lt5_1060</b>
Scale: 1 : 5	
Date: 20 December 2018	