



Notes:

- Foam closure strip only required if bird or vermin proofing is required, or if in a high wind area, there is a risk of windblown moisture entering the building.
- Leave foam out if ventilation is required.
- These details are suitably fixed to allow for a theoretical thermal movement of up to 10mm. For thermal movement greater than this a clipping system should be considered.

Original Size A4



Steelspan 900

Wall

Horizontal Cavity Cladding - Wall/Roof Junction

dim_sp9_2180 Horizontal Cavity Cladding - Wall/Roof Junction	
Issue: 01	Reference dim_sp9_2180
Scale: 1 : 5	
Date: 20 December 2018	