



**Notes:**

- Foam closure strip only required if bird or vermin proofing is required, or if in a high wind area, there is a risk of windblown moisture entering the building.
- Leave foam out if ventilation is required.
- These details are suitably fixed to allow for a theoretical thermal movement of up to 10mm. For thermal movement greater than this a clipping system should be considered.
- Where CCA or ACQ treated cavity battens are installed a barrier between the batten and the cladding is required.

Original Size A4



## Six Rib Wall

Horizontal Cavity Cladding - Wall/Roof Junction

dim_sxr_2180 Horizontal Cavity Cladding - Wall/Roof Junction	
Issue: 01	Reference <b>dim_sxr_2180</b>
Scale: 1 : 5	
Date: 20 December 2018	