

Apex flashing fixed to roof with 12g x 25mm T17 or 4.8 dia aluminium rivets at every rib

Notched flashing

Climaseal coated self drilling M6 x 50 Roofzip rib fixed

Dimond Veedek® roofing (specify thickness and coating)

Roofing underlay and netting shown dashed

130 mm min. medium wind speed areas or pitches greater than 10°.  
200 mm min. high wind speed areas and higher or pitches less than 10°.

DHS girt

Line of structure

Notes:

- Foam closure strip only required if bird or vermin proofing is required, or if in a high wind area, there is a risk of windblown moisture entering the building.
- Leave foam out if ventilation is required.
- These details are suitably fixed to allow for a theoretical thermal movement of up to 10mm. For thermal movement greater than this a clipping system should be considered.

Dimond Veedek® stop ended

Dimond Veedek® stop ended

100 mm min. lap

Climaseal coated self drilling 12g x 25mm T17 screw pan fixed

Foam closure strip on top of roofing (see note below)

Framing shown dashed for clarity

Dimond hi-span steel wall girt

Climaseal coated self drilling M6 x 25 Roofzip pan fixed

Dimond Veedek® wall cladding (specify thickness and coating)

Building wrap shown dashed

Original Size A4

File:	
Issue:	01
Scale:	1 : 5
Date:	28 November 2018
Reference	dim_vde_1060